## Pilesgrove Township Certificate of Occupancy Inspection Checklist

| Block:   |          | Lot: Address:  |
|----------|----------|--|
| Name:    |          | Phone:   |
| Date Ins | spected: | Date Re-Inspected:   |
|          | 1.       | House Numbers to measure 5" in height and be visible from the street.  |
|          | 2.       | Smoke detectors on each level; in every bedroom, including basement.   |
|          | 3.       | CO detector within 10' of every bedroom.   |
|          | 4.       | GFI protected outlets within 6' of water source and on all exterior outlets.   |
|          | 5.       | Fire Extinguisher mounted in kitchen.  |
|          | 6.       | All appliances must be installed properly and be in proper working order.<br>No extension cords. (stoves, exhaust fans, etc) |
|          | 7.       | Exhaust fan over stove (ductless hood is permissible).   |
|          | 8.       | Anti-tip bracket installed on stove.   |
|          | 9.       | Adequate electric, heating and plumbing service.   |
|          | 10.      | Bathroom must be vented or have an operating window.   |
|          | 11.      | Screened window in each room.  |
|          | 12.      | All windows must be operational with lock.   |
|          | 13.      | Two separate electrical outlets in each habitable room.  |

| <br>14. | Handrails on all steps with more than 3 risers and all landings or porches 30" in height or higher must have a rail around entire area.                            |
|---------|--|
| <br>15. | Exterior doors and hardware must be operational.   |
| <br>16. | Water heater's pressure relief valve must be piped to within 6" of floor.  |
| <br>17. | Emergency shut-off at top of stairs for heater located in basement.  |
| <br>18. | In-ground pool must have at least 4' high fence and be self latching.  |
| <br>19. | House must be free of insect infestation.  |
| <br>20. | Work done without permits? YES NO  |
| <br>21. | Open construction permits? YES NO  |
| <br>22. | Well / water test = PASS? YES NO   |
| <br>23. | Septic inspection = PASS? YES NO   |
| <br>24. | Chimney Inspection = PASS? YES NO  |
| <br>25. | Effective July 22, 2022, a rental home built before 1979 needs a lead safe/free certificate from the approved NJ Licensed Certified Lead Contractor = PASS? YES NO |
| <br>26. | Effective August 5, 2022, proof of Property Liability Insurance for rentals ( <i>pursuant to Title 40A:10A-1 et seq</i> ) = Submitted? YES NO                      |

Housing Official: Tanya Timberman

## 48 Hours notice is required for inspection.

This list is intended as a guide and is not to be considered all inclusive. An application along with the fee must be submitted prior to scheduling an inspection/re inspection. The owner or agent must call to schedule an inspection. Residential CO inspections require a fee of \$50.00. NO Temporary CO's will be issued.